

File No:

FILE

3373010

**CHECK LIST****RESIDENTIAL SWIMMING POOLS**

P14964

OWNER'S NAME: L. M. ClarkeADDRESS: 616 Te Ngae Rd

INSPECTION DATE:

VALUATION NO: 06993/401.00

P14964

	Complies	Non-complying	Comments
A. All fences shall extend a minimum of 1.2 above ground level on the outside of the fence.			
B. All fences shall be 1.2 metres above any permanent projection or permanent object located at ground level outside and within 1.2 metres of the fence.			
C. Where the fence is constructed of netting or mesh, any opening in the material greater than 10 mm, the fence will be required to be 1.8 metres in height.			
D. Where any netting or mesh is used no opening in the material is to be greater than 50 mm (no exemptions).			
E. Maximum clearance between the underside of any fence shall not exceed 100 mm.			
F. The fence must be durable and erected so as to inhibit any person from climbing over or under the fence.			
G. Where vertical pales or panels are used, spacings between each pale or panel shall be no greater than 100 mm.			
H. All support rails, rods wires bracing shall be on the inside of the fence "only" (no exemptions). However, a fence may have horizontal supports etc. which are accessible for climbing from outside the pool, if any two of them are separated by a distance of at least 900mm between each rail and there is no other support etc. (other than a vertical rail) between the two.			
I. All materials used in fence construction shall be firmly attached at the top and the bottom, to rails, pipe or similar structures so as to prevent access to the pool area by children under six years of age.			

Not Compliant
 Council 23/10/98

GATES AND DOORS

A. All gates or doors entering a pool enclosure are required to open in an outward direction only?			
B. Be clear of any obstruction that could hold the gate or door in an open position.			
C. When lifted up or pulled down, the gate or door does not release the latching mechanism, come off its hinges or provide a ground clearance greater than 100 mm.			
D. All gates or doors are required to be fitted with a secure latching device.			
E. If the latching device is located on the inside of the fence or gate openable by either reaching over or through a hole in the fence the latch shall be at least 1.2 metre above ground level.			
F. If the latching device is outside the fence the latch shall be mounted no lower than 1.5 metres above ground level.			
G. Every gate is required to be fitted with an automatic closing device that will allow the gate to return to a fully closed position, and latch from a distance no greater than 150 mm away from the closed and secured position.			

COMPLIES:Non-complying ☐ Inspected by:..... Checked by:.....

616 Te Ngae Rd

FILE COPY

P 14964

File No: ~~8363010~~ROTORUA
DISTRICT
COUNCILPrivate Bag RO 3029
Rotorua
New Zealand
Telephone 07-348 4199
Fax 07-346 3143
E-mail mail@rdc.govt.nzAddress all
communications to:
District Manager
Rotorua District Council**ATTENTION PROPERTY OWNER/S**

The Council has recently updated the Register of Swimming Pools and your property has been identified as having a pool located on it.

To assist us to ensure the information is correct, please check the attached licence, complete this form and return to Council in the prepaid envelope provided.

Your assistance will be much appreciated.

MY / OUR PROPERTY HAS:**TICK APPROPRIATE
BOX**

A Spa Pool

☐

A Swimming Pool

☐

A Public Pool

☐

A School Pool

☐

Does not have a Pool

☒

(Council has identified the wrong property)

CANCELLED
23/10/98 LS**Any Comments: (Please State Items Relevant to Your Pool)**

Haven't had a pool in the 5 years
we've been here!

SISTER CITIES:
Klamath Falls, Oregon, U.S.A.
Beppu City, Oita, Japan.
Lake Macquarie, NSW, Australia