

17 High Street Street Lot 10 DPS 23730 Section Block

ROTORUA DISTRICT COUNCIL



REG

Sanitary Plumbing to Super Tub & Sink

Owner: G.Gainsford

Valuation No.: 652/578

Plumber: S.Churches

Permit No.: 5302

Drainlayer:

Appn. No.: 2466

INSPECTIONS

Date: 5/3/82

Date

28-9-82

*Work inspected & tested
Plumbing Comp. Ltd.*



ROTORUA DISTRICT COUNCIL

Valuation No. 652/578

APPLICATION FOR PERMIT TO CARRY OUT SANITARY PLUMBING AND DRAINAGE WORK

I, the undersigned, hereby apply for permission to have the work described herein, and set out on the plans attached hereto, carried out in accordance with the provisions of the Drainage and Plumbing Regulations 1978 and Amendments at premises situated at:

Address

17 High Street Rotorua

Legal Description:

Lot No.

10

Deposited Plan No.

23730

Section No.

Block No.

Description of Work:

Installing pipe work for super
tub + sink

Name and address of person for whom work is to be carried out:

G.W. Gainsford 17 High Street

Name and address of Registered Plumber:

S.G. Churches Ltd

16 Lewis Rd Lynmore

Name and address of Registered Drainlayer:

	Value	Fees
Plumbing	\$ 190 :	\$ 32 :00
Drainage	\$:	\$:
TOTAL FEES		\$ 32 :00

Signature:

S.G. Churches

Date:

26 Feb 1982

FOR OFFICE USE ONLY

Receipt Number

8498

Fee Paid

832-00

Date Paid

5-3-82

Issue Approved

Ray G

Date Approved

5-3-82

Permit No.

5302

Date Issued

See reverse for Fees and Notes

FOR OFFICE USE ONLY

FEES PAYABLE ON THE ISSUE OF ANY PLUMBING OR DRAINAGE PERMIT

according to the Estimated Value of Work

Value of work (excluding value of fittings)	
Value of Work	Permit Fee
Up to \$50	\$15
\$51 - \$100	\$20
\$101 - \$200	\$32
\$201 - \$300	\$38
\$301 - \$400	\$44
\$401 - \$500	\$50
\$501 - \$600	\$56
\$601 - \$700	\$62
\$701 - \$800	\$68
\$801 - \$900	\$75
\$901 - \$1000	\$80
\$1001 and over, \$7 extra for every \$200 or part thereof in excess of \$1000	

IMPORTANT

INSPECTION AND TESTING REQUIREMENTS

DRAINAGE WORK: Drainlayers are required to notify the Plumbing and Drainage Inspector when all work is completed. This includes effluent disposal systems for septic tanks. All drains will be tested with a 1.5 m head of water. To implement this test it will be necessary for persons undertaking drainage work to have sufficient drain plugs to fill all sections of the drain prior to the Plumbing and Drainage Inspector arriving on the job, also to have available a stand pipe to apply the 1.5 m head pressure.

This form of testing is essential to exclude the possibility of ground water infiltration with its attendant increase in pumping charges and overloading of the sewers and treatment plant.

PLUMBING WORK: Plumbers are required to notify the Plumbing and Drainage Inspector when work is ready for inspection as follows:

- (a) When the building has been initially piped out and wastes are installed (before wall linings are fixed and floors laid).
- (b) When work is complete.
- (b) When work is complete.

Plans of Drainage and Plumbing Work

In the case of single houses a preliminary drainage plan will not be required. In all other cases, however, plans of the preliminary proposal are to be submitted at the time of application for a permit. In all instances, however, an "as laid" plan must be available on site as a prerequisite to a test of the work.

In commercial buildings full plans and elevations of plumbing stacks must be provided at the time of application for a permit.


Plans MUST show dimensions and distances from section boundaries in metric units

Rotorua City Council

DRAINAGE PLAN

NEW SEWERAGE DRAINS — RED
STORMWATER — DOTTED BLACK
OLD DRAINS — FULL BLACK

652/578



OWNER M^{rs} GAINSFORD.

No. 17 STREET HIGH ST.

LOT _____ SEC. _____ BL. _____

SIGNATURE

OF DRAINLAYER

S.G. Churches DATE 28/9/82