

17 High Street Lot 10 DPS 23730 Section Block

**ROTORUA CITY COUNCIL**



REG

Drainage to Sewer

Owner: F. Gainsford 1484

Valuation No.: 652/578

Plumber:

Permit No.: 6540

Drainlayer: Norris & Breen

Appn No.: 5018

**INSPECTIONS**

19-11-75

Date

20-11-75

*Drainage Tested (Existing drains OK)*





5018

# CITY OF ROTORUA

Valuation No. 652 / 578

**APPLICATION FOR PERMIT TO CARRY OUT SANITARY PLUMBING AND DRAINAGE WORK**  
I, the undersigned, hereby apply for permission to have the work described herein and set out on the plans attached hereto, carried out in accordance with the provisions of the Drainage and Plumbing Regulations 1959 at premises situated at:

Address 17 High St ROTORUA

**Legal Description:**

Lot No. 10 Deposited Plan No. 23730

Section No. \_\_\_\_\_ Block No. \_\_\_\_\_

Description of Work: Connect drainage to Council Sewer

Name and address of Person for whom work is to be carried out:

Mr. F.L.H. Gainsford 17 High St ROTORUA

Name and address of Registered Plumber: \_\_\_\_\_

Name and address of Registered Drainlayer: FRANK NORTH & BRENN LTD.

Box 596

ROTORUA

PLUMBING		
DRAINAGE	<u>155</u>	
TOTAL	<u>155</u>	<u>03-00</u>

Signature: Adolf Green

Date: 19/11/75

Value of Work including Materials:

~~Plumbing: \$ \_\_\_\_\_~~  
~~Drainage: \$ \_\_\_\_\_~~  
~~Total: \$ \_\_\_\_\_~~  
~~Fee Enclosed: \$ \_\_\_\_\_~~

See reverse for Fees and Notes.

**FOR OFFICE USE ONLY**

Date Received 19-11-75

Fee Paid 3-00 148931

Date Paid 19-11-75

Issue Approved [Signature]

Date Approved 19/11/75

Permit No. 6540

Date Issued 19-11-75

**FOR OFFICE USE ONLY**

**FEES PAYABLE ON THE ISSUE OF ANY PLUMBING OR DRAINAGE PERMIT**  
according to the Estimated Value of Work

Value of work (including value of fittings)

Dollars	Dollars
up to 100	1.50
101 - 200	3.00
201 - 400	6.00
401 - 600	8.00
601 - 800	10.00
801 - 1000	12.00
1001 - 1200	14.00
1201 - 1400	16.00
1401 - 1600	18.00
1601 - 1800	20.00
1801 - 2000	22.00

2001 and over, 1 dollar extra for every \$200 or part thereof in excess of 2000 dollars.

**IMPORTANT**

**INSPECTION & TESTING REQUIREMENTS**

**Drainage Work:** Drainlayers are required to notify the Plumbing and Drainage Inspector when all work is completed. This includes effluent disposal systems for septic tanks. All drains will be tested with a 5ft head of water. To implement this test it will be necessary for persons undertaking drainage work to have sufficient drain plugs to fill all sections of the drain prior to the Plumbing and Drainage Inspector arriving on the job, also to have available a stand pipe to apply the 5ft head pressure.

This form of testing is essential to exclude the possibility of ground water infiltration with its attendant increase in pumping charges and overloading of the sewers and treatment plant.

**Plumbing Work:** Plumbers are required to notify the Plumbing and Drainage Inspector when work is ready for inspection as follows:


- (a) When the building has been initially piped out and wastes are installed (before wall linings are fixed and floors laid).
- (b) When work is complete.

**Plans of Drainage and Plumbing work:**

In the case of single houses a preliminary drainage plan will not be required. In all other cases, however, plans of the preliminary proposal are to be submitted at the time of application for a permit. In all instances, however, an "as laid" plan must be available on site as a prerequisite to a test of the work.

In commercial buildings full plans and elevations of plumbing stacks must be provided at the time of application for a permit.

~~656/375/48.~~  
652/578.



OWNER Transport LOT ~~10~~ 10 SEC. 23750 BL.

No. 17 STREET High St SIGNATURE 22

OF DRAINLAYER *69/ham* DATE *20/11/75*

CITY OF ROTORUA

APPLICATION FOR NEW SEWERAGE RETICULATION CONNECTION

APPLICATION NO.

1484

VALUATION NO.

652/578

I We FRANCIS IVOR HEWITT GAINSFORD  
GEORGINA WINIFRED GAINSFORD  
of 14 High St. ROTORUA  
(Postal Address)

hereby apply for permission to couple to the City  
our  
Sewerage Scheme on my property being:

Lot No. 10 (D.P.S.) D.P. 23730

Section No. Block No.

Situated in: HIGH ST Street  
us  
owned by me and at present in the occupation of:

Signature of Applicant :

Date: 11/11/1975

FEES PAYABLE

4" Connection \$70.00

6" Connection \$70.00

Any additional costs charged out to applicant

FOR OFFICE USE ONLY

EXAMINED

DRAINAGE INSPECTOR

FEE PAID

\$70.00

RECEIPT NO.

23647

DATE

11-11-75

